

# SERVICE LINE INSTALLATION STANDARDS

10' separation between waterline and any sewer or septic system

18" separation between waterline and sewer line if crossing is necessary

3' separation between electric lines and waterline when running parallel

LPRW will install a meter pit for all new installations, material and labor costs are factored into the cost estimate.

LPRW crew has the right to dig an OSHA safe trench on your property

LPRW will to the best of their ability do a onetime clean up to the area disturbed at the time of installation. Subsequent filling, leveling, or other dirt work will be the owner's responsibility.

LPRW will not be responsible for damage done to obstructions placed over our trench after construction is complete and may refuse to perform service work on lines below or adjacent to these obstructions.

Service line valves are to remain accessible to LPRW personnel and adequately marked for easy identification.

## ADDITION FOR LIVESTOCK

Any new member, connecting to LPRW that purchases more than one capacity unit (50,000 gallons per month), and/or utilizes over 50,000 gallons in any month is required to have on-site storage equivalent to 24-hour peak usage.

One Capacity Unit currently allows you up to 50,000 gallons of water a month. Capacity Charges currently cost \$10,000 per Capacity Unit, and one Capacity Unit is currently included in the basic hookup charge of \$16,500.

By signing this document, you understand that when or if you go over your capacity limit you will have the following options to consider: 1.) reduce the usage to below your capacity limits, or 2.) pay for additional capacity at the current rate, or 3.) pay an overage charge which is currently \$5.00 per 1,000 gallons used over your capacity limit.